

# Flexibility to support the grid

Rixhon Daniel & Bastin Bertrand

22/06/2022



[www.cet-power.com](http://www.cet-power.com)



Belgium, Luxembourg, China, India,  
United States, United Kingdom, France,  
Germany, United Arab Emirates, Russia,  
Malaysia, Australia.




A graphic featuring a white globe with a red circular brushstroke around it, set against a grey background. The text "energy transition" is written in a bold, black, sans-serif font with a white outline, positioned in the center of the globe.

**energy  
transition**

# 1.5

---



Energy  
Efficiency

+



Renewable  
Electricity

+




Strategic  
Electrification

=

**Pathway To Decarbonization**

(80% Reduction in GHG emissions by 2050)

Emissions  
(GtCO<sub>2</sub>)



The impact on emissions of replacing fossil fuels with renewables and increasing energy efficiency through 2030



**50**


---

## ✓ Secondary energy

- Easy conversion / tricky storage

## ✓ Disruption

- Disaster, domino effect : transportation, communication, finance, ... **safety !**




### BESS systems located near load :




- ✓ Less siting challenges
- ✓ Reduce transmission & distribution losses
- ✓ Relieve congestions
- ✓ Defer transmission & distribution upgrades


#### Directive 2019/944 (EMDII)

##### Aggregation

- The directive provides a dedicated framework for aggregators to increase the participation of individuals to the demand response
- Aggregators should be treated as flexibility providers









*EU Commission is proposing to forbid sales of cars with combustion engines by 2035*


**Table 10: Europe's Five Largest Economies National Electric Car Deployment 2030-2050 Targets**

Country	2030	2040	2050
France	3 million BEVs, 1.8 million PHEVs (2028)	No sales of new cars and vans using fossil fuels	X
Germany	7-10 million BEVs, FCEVs	X	All passenger vehicle sales to be ZEVs
Italy	4 million BEVs, 2 million PHEVs	X	X
Spain	5 million EVs	100% ZEV sales	X
UK	No sales of new ICE (2030)	X	X


Relative to vehicle stock  
 Full ICE phase out or 100% EV target

Average charging power [kW]

Weekdays



Weekends




**25,000 TW.HR**

---

## BESS systems located near load :



- ✓ Less siting challenges
- ✓ Reduce transmission & distribution losses
- ✓ Relieve congestions
- ✓ Defer transmission & distribution upgrades



# **ANCILLARY SERVICES EXAMPLE : AUSTRALIA**

---

# Focus on fast frequency responses



Application	Description	Duration of Service Provision
Arbitrage	Purchasing low-cost off-peak energy and selling it during periods of high prices	Hours
Firm Capacity	Provide reliable capacity to meet peak system demand	4+ hours
Operating reserves		
Primary Frequency response	Very fast response to unpredictable variations in demand and generation	Seconds
Regulation	Fast response to random, unpredictable variations in demand and generation	15 minutes to 1 hour
Contingency Spinning	Fast response to a contingency such as a generator failure	30 minutes to 2 hours
Replacement/Supplemental	Units brought on line to replace spinning units	Hours
Ramping/Load Following	Follow longer-term (hourly) changes in electricity demand	30 minutes to hours
Transmission & Distribution Replacement & Deferral	Reduce loading on T&D system during peak times	Hours
Black-Start	Units brought on line to start system after a system-wide failure (blackout)	Hours


# Frequency ancillary services: example for Australia

## Contingency


1. Fast raise
2. Fast lower
3. Slow raise
4. Slow lower
5. Delayed raise
6. Delayed lower

## Regulation

1. Regulation raise
2. Regulation lower



# Contingency – Fast raise



- Stop fast fall of grid frequency
- Amount of power is pre-defined
- Work locally


RoCoF

Rate of change of frequency

nadir

Measure the minimum post contingency frequency

# Contingency – Fast raise



RoCof & Nadir = Influence on tripping of other components.

Technologies	Hydro	Wind & Solar	Nuclear	Gas power plant	Batteries
Reaction time	1-2 minutes	Not possible	Hours	5-30 minutes	< 1 s

# Contingency – Fast raise






Figure 4 — Timing, step response time and settling time

# THE SPOT MARKET

---

- Use a model that predicts the future imbalance of the grid
- The model uses a variety of input data
  - **Climate Data** (e.g., wind & solar)
  - **Grid Data** (e.g., load, imbalance)
  - **Market Data** (e.g., spot & imbalance prices)
- A decision-based model based on domain knowledge boosted with artificial intelligence




# Belgium - Record day April 21 - 2021


Pumped hydro storage under maintenance



Lower winds than expected




Power station disruption



**Imbalance prices**

Source : elia  
| Elia Group

Imbalance Price (€/MWh)	
Minimum	Maximum
-487.07	3,199.94




4300€ / MW.hrs



13 Jun 2022, 1:00 AM AEST

Default	Power MW	Contribution to demand	AV Value \$/MWh
<b>Sources</b>	<b>21,575</b>		<b>\$551.00</b>
Solar (Rooftop)	0	0.0%	-
Solar (Utility)	0.1	0.0006%	-
Wind	1,850	6.4%	-
Hydro	3,579	16.6%	-
Battery (Discharging)	3.8	0.02%	-
Gas (Waste Coal Mine)	66	0.3%	-
Gas (Reciprocating)	174	0.8%	-
Gas (OCGT)	367	1.7%	-
Gas (CCGT)	1,841	8.5%	-
Gas (Steam)	674	5.1%	-
Distillate	34	0.2%	-
Bioenergy (Biomass)	-0.6	-0.003%	-
Coal (Black)	9,926	46.0%	-
Coal (Brown)	3,550	16.4%	-
<b>Loads</b>	<b>-25.5</b>		
Pumps	0	0.0%	-
Battery (Charging)	-25.5	-0.1%	-
<b>Net</b>	<b>21,551</b>		
Renewables	4,958	23.0%	



# SIERRA AT WORK


---



Orison Panel  
2.2 kWh Scalable Battery




- **HIGHLY COST Effective Solution**
- **Scalable 2.2kW/hr Battery**
- **Plugs Directly into standard GPO**
- **Minimal Installation Costs**
- **Battery Expansion easily Implemented.**
- **Open Integration to cloud Demand Management platform**
- **International Standards Approved**



NextGen SIERRA Power Train 240kW Battery cabinet 10U/16U 4 cooler

Battery cabinet 4x150Ah LVD-Battery breaker  
 Battery cabinet 4x150Ah LVD-Battery breaker  
 Battery cabinet 4x150Ah LVD-Battery breaker  
 DC distribution to IT equipment 20kVDC  
 SIERRA converter cabinet 120 kW / 45 module 2,7kW  
 SIERRA converter cabinet 120 kW / 45 module 2,7kW





\*Recharges in 3 hours between 20 and 80% DOD, Average 50 kWh battery



**FLEXIBILITY**

Thank you  
for your attention

Check our website

**[www.cet-power.com](http://www.cet-power.com)**

Follow us

